

[Validate](#)
[Print](#)
[Help](#)

Item Rate BoQ

Tender Inviting Authority: ITPO Pragati Maidan New Delhi-110001.

Name of Work: Supply, Installation, Testing and Commissioning of Air Curtains at exhibition halls at ITPO, Pragati Maidan, New Delhi

Contract No: 167-ITPO(16)E-E/23-24/10

Name of the Bidder/ Bidding Firm / Company							
<div>PRICE SCHEDULE</div> <div>(This BOQ template must not be modified/replaced by the bidder and the same should be uploaded after filling the relevant columns, else the bidder is liable to be rejected for this tender. Bidders are allowed to enter the Bidder Name and Value only)</div>							
NUMBER #	TEXT #	NUMBER #	TEXT #	TEXT #	NUMBER #	NUMBER #	TEXT #
Sl. No.	Item Description	Quantity	Units	Quoted Currency in INR or Other Currency	BASIC RATE WITH ALL TAXES INCLUDING GST In Figures To be entered by the Bidder in Rs. P	TOTAL AMOUNT WITH ALL TAXES INCLUDING GST in Rs. P	TOTAL AMOUNT IN Words
1	2	4	5	12	13	53	55
1	Supply, installation, testing and commissioning of stainless steel centrifugal air curtain having following specification. The product should be made up stainless steel 304Grade having 4 Blowers(in ABS), 2 Motors operating on single phase , Power =560 Watt having RPM (Max/Min = 2700/2100) and having CFM of 1100. Overall Dimension of 1200X230X212(mm) with Noise level = 60 - 70 db. Air Curtain should be provided with velocity control switch and a Door sensor. The product should carry manufacturers warranty of one year from the Date of Supply. Along with Fabrication work of providing 2/1 MS Pipe , Tin Sheet as cover, Bracketed and screws *Variations acceptable in parameters above - 5-10% The Product should be complete in all aspect as per Engineer incharge instructions.	64.000	Set	INR		0.00	INR Zero Only
2	Supply, installation, testing and commissioning and placing of stainless steel centrifugal air curtain having following specification. The product should be made up stainless steel 304Grade having 5 Blowers(in ABS), 3 Motors operating on single phase , Power <700 Watt having RPM (Max/Min = 2700/2100) and having CFM of 1380. Overall Dimension of 1500X230X212(mm) with Noise level = 60 - 70 db. Air Curtain should be provided with velocity control switch and a Door sensor. The product should carry manufacturers warranty of one year from the Date of Supply.Along with Fabrication work of providing 2/1 MS Pipe , Tin Sheet as cover, Bracketed and screws *Variations acceptable in parameters above - 5-10% The Product should be complete in all aspect as per Engineer incharge instructions.	34.000	set	INR		0.00	INR Zero Only
3	Supply, installation, testing and commissioning and placing of stainless steel centrifugal air curtain having following specification. The product should be made up stainless steel 304Grade having 3 Blowers(in M. Steel), 2 Motors operating on three phase , Power =1650 Watt having RPM (Max/Min = 2700) and having CFM of 2350. Overall Dimension of 1218X345X351(mm) with Noise level < 66 db. Air Curtain should be provided with velocity control switch and a Door sensor. The product should carry manufacturers warranty of one year from the Date of Supply. Along with Fabrication work of providing 2/1 MS Pipe , Tin Sheet as cover, Bracketed and screws *Variations acceptable in parameters above - 5-10% The Product should be Supplied along with PVC curtains & SS Bracket for PVC Support. Supply, installation, testing and commissioning of transparent blue PVC Strip curtain, these medium weight strip will help with temperature control or dust exclusion without impeding access. It is suitable for the door is the main entry gate of the premises, means exposed to air. It is commonly used in Pharmaceutical Industries,Manufacturing Plants,Dairy Industry,Factories,Warehouses,Health Care Facilities etc. The Product should be complete in all aspect as per Engineer incharge instructions.	22.000	Nos.	INR		0.00	INR Zero Only
4	Supply, installation, testing and commissioning and placing of stainless steel centrifugal air curtain having following specification. The product should be made up stainless steel 304Grade having 4 Blowers(in M. Steel), 2 Motors operating on three phase , Power =2200 Watt having RPM (Max/Min = 2700) and having CFM of 3680. Overall Dimension of 1523X345X351(mm) with Noise level < 68 db. Air Curtain should be provided with velocity control switch and a Door sensor. The product should carry manufacturers warranty of one year from the Date of Supply. Along with Fabrication work of providing 2/1 MS Pipe , Tin Sheet as cover, Bracketed and screws The product should be supplied along with PVC curtains & SS Bracket for PVC Support. Supply, installation, testing and commissioning of transparent blue PVC Strip curtain,these medium weight strip will help with temperature control or dust exclusion without impeding access. It is suitable for the door is the main entry gate of the premises, means exposed to air. It is commonly used in Pharmaceutical Industries,Manufacturing Plants,Dairy Industry,Factories,Warehouses,Health Care Facilities etc. The Product should be complete in all aspect as per Engineer incharge instructions.	10.000	Nos.	INR		0.00	INR Zero Only
Total In Figures						0.00	INR Zero Only
Quoted Rate in Words						INR Zero Only	