

Corrigendum for Minutes of Pre bid meeting

Sub: Supply, Installation, Testing and commissioning of Cooling Towers along with connecting accessories of HVAC plant for Hall No. 8-11 and 12-12A at Pragati Maidan, New Delhi.

Ref. NIT No.169-ITPO(1)/E-E/20-21/2073 dated 29.01.2021 the pre bid meeting held on 04.02.21 for above mentioned work and following agencies attended the same through Video Conference .

- **M/s-DELTA COOLING TOWER INDIA PVT. LTD.**
- **M/s- Accurate Engineers**
- **M/s-HV Air-conditioning Systems Pvt. Ltd.**
- **M/s-WELDON ENGINEERS (INDIA)**
- **M/s-Dexter23 Building Solutions**
- **M/s-Voltas Limited**
- **M/s-WELCOME ENGINEERS**

The agencies discussed all the related issues and get clarified on the spot and confirmed the following.

S. No	NIT PAGE No.	EXISTING PROVISION	May be read as
1	22-23	<p style="text-align: center;"><u>BOQ ITEM NO.1</u></p> <p>Supply Installation Testing and Commissioning of Induced draught counter flow FRP Cooling Tower of 562.5TR for 450TR Chiller capacity having heat rejection capacity of 17,01,000Kcal/hr</p> <p>.....</p> <p>Motor make: ABB/Havells/Hindustan/New India Cooling Tower Make: BELL/MIHIR/PAHARPUR/DELTA</p>	<p style="text-align: center;"><u>BOQ ITEM NO.1</u></p> <p>Supply Installation Testing and Commissioning of Induced draught counter flow FRP Cooling Tower of 562.5TR for 450TR Chiller capacity having heat rejection capacity of 17,01,000Kcal/hr</p> <p>.....</p> <p>Motor make: ABB/Havells/Hindustan/New India/Siemens Cooling Tower Make: BELL/PAHARPUR/DELTA</p>

NOTE: Electrical starter (Star-Delta), Electrical Cables and earthing from electrical panel to cooling tower and Electrical Cable tray will be replaced and comes under scope of work for that no extra payment will be given .


08/02/2021

Manager(Elect.)
I.T.P.O Pragati Maidan, New Delhi